



Product Service

CERTIFICATE

No. Z2 001256 0005 Rev. 05

Holder of Certificate: **Win Win Precision Technology Co., Ltd.**
4F., No.180, Sec/2, Gongdao 5th Road
East Dist.
30070 Hsinchu City
TAIWAN

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 614101801306

Valid until: 2026-08-15

Date, 2021-08-16

(Louis Wu)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

CERTIFICATE

No. Z2 001256 0005 Rev. 05

Model(s):

- WSP-xxxM6, xxx = 170~200 in step of 5 (for 36 cells)
 - WSP-xxxM6, xxx = 225~265 in step of 5 (for 48 cells)
 - WSP-xxxM6, xxx = 255~300 in step of 5 (for 54 cells)
 - WSP-xxxM6, xxx = 280~335 in step of 5 (for 60 cells)
 - WST-xxxM6, xxx = 170~200 in step of 5 (for 36 cells)
 - WST-xxxM6, xxx = 225~265 in step of 5 (for 48 cells)
 - WST-xxxM6, xxx = 255~300 in step of 5 (for 54 cells)
 - WST-xxxM6, xxx = 280~335 in step of 5 (for 60 cells)
 - WSP-xxxMX, xxx = 180~200 in step of 5 (for 36 cells)
 - WSP-xxxMX, xxx = 240~270 in step of 5 (for 48 cells)
 - WSP-xxxMX, xxx = 270~305 in step of 5 (for 54 cells)
 - WSP-xxxMX, xxx = 300~340 in step of 5 (for 60 cells)
 - WST-xxxMX, xxx = 180~200 in step of 5 (for 36 cells)
 - WST-xxxMX, xxx = 240~270 in step of 5 (for 48 cells)
 - WST-xxxMX, xxx = 270~305 in step of 5 (for 54 cells)
 - WST-xxxMX, xxx = 300~340 in step of 5 (for 60 cells)
 - WSP-xxxM6G, xxx = 170~200 in step of 5 (for 36 cells)
 - WSP-xxxM6G, xxx = 225~265 in step of 5 (for 48 cells)
 - WSP-xxxM6G, xxx = 255~300 in step of 5 (for 54 cells)
 - WSP-xxxM6G, xxx = 280~335 in step of 5 (for 60 cells)
 - WST-xxxM6G, xxx = 170~200 in step of 5 (for 36 cells)
 - WST-xxxM6G, xxx = 225~265 in step of 5 (for 48 cells)
 - WST-xxxM6G, xxx = 255~300 in step of 5 (for 54 cells)
 - WST-xxxM6G, xxx = 280~335 in step of 5 (for 60 cells)
 - WSP-xxxMG, xxx = 355~380 in step of 5 (for 120 cells)
 - WST-xxxMG, xxx = 355~380 in step of 5 (for 120 cells)
 - WSP-xxxMG, xxx = 320~335 in step of 5 (for 108 cells)
 - WSP-333MG (for 108 cells)
 - WST-xxxMG, xxx = 320~335 in step of 5 (for 108 cells)
 - WST-333MG (for 108 cells)
 - WSP-xxxMGL, xxx = 355~380 in step of 5 (for 120 cells)
 - WST-xxxMGL, xxx = 355~380 in step of 5 (for 120 cells)
 - WSP-xxxMGL, xxx = 320~335 in step of 5 (for 108 cells)
 - WSP-333MGL (for 108 cells)
 - WST-xxxMGL, xxx = 320~335 in step of 5 (for 108 cells)
 - WST-333MGL (for 108 cells)
- xxx is standing for rated output power at STC



CERTIFICATE

No. Z2 001256 0005 Rev. 05

Brand Name: WINAICO

Parameters:

Rated output power at STC: See below
Construction: Framed, with Junction box, Cable and Connectors.
Safety Class: Class II
Pollution Degree: 2
Module fire performance: Type 4 according to UL 1703
Fire safety class: C according to UL 790
Maximum System voltage: 1000 VDC
Test Laboratory: Telecom Technology Center Communication and Photovoltaic Laboratory- Telecom Technology Center No.3, Luke 1'st Rd., Lujhu, Kaohsiung city, Taiwan, CHINESE TAIPEI

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 EN 61215-1:2016
 EN 61215-1-1:2016
 EN 61215-2:2017
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06