




Product Service

CERTIFICATE

No. Z2 001256 0011 Rev. 00

Holder of Certificate: **Win Win Precision Technology Co., Ltd.**
4F., No.180, Sec/2, Gongdao 5th Road
East Dist.
30070 Hsinchu City
TAIWAN

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 614102003501

Valid until: 2026-07-21

Date, 2021-07-26

(Louis Wu)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



CERTIFICATE

No. Z2 001256 0011 Rev. 00

Model(s):

WSP-xxxMG, xxx = 355~380 in step of 5 (for 120 cells)
 WST-xxxMG, xxx = 355~380 in step of 5 (for 120 cells)
 WSP-xxxMG, xxx = 320~335 in step of 5 (for 108 cells)
 WSP-333MG (for 108 cells)
 WST-xxxMG, xxx = 320~335 in step of 5 (for 108 cells)
 WST-333MG (for 108 cells)
 WSP-xxxMGL, xxx = 355~380 in step of 5 (for 120 cells)
 WST-xxxMGL, xxx = 355~380 in step of 5 (for 120 cells)
 WSP-xxxMGL, xxx = 320~335 in step of 5 (for 108 cells)
 WSP-333MGL (for 108 cells)
 WST-xxxMGL, xxx = 320~335 in step of 5 (for 108 cells)
 WST-333MGL (for 108 cells)
 xxx is standing for rated output power at STC

Brand Name: WINAICO

Parameters:

Construction: Framed, with Junction box, Cable and Connectors.
Safety Class: Class II
Pollution Degree: 2
Maximum System voltage: 1000 VDC
PID stress test condition: ±1000 V DC, 85°C, RH 85%, 96h
Test Laboratory: Industrial Technology Research Institute
 Rm. 168, Bldg. 21, No 195, Sec.4, Chung Hsing Rd.
 Chutung Hsinchu, 310 Taiwan CHINESE TAIPEI

Remark: PPP 58042B:2015 is identical to IEC TS 62804-1:2015

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 PPP 58042B:2015